


Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie
Direktor: Prof. Dr. rer. nat. L. Dunemann

Hygiene-Institut, UMWELT Postfach 10 12 55 · 45812 Gelsenkirchen



Rotthauer Str. 21
45879 Gelsenkirchen

Telefon (0209) 9242-0
Telefax (0209) 9242-222
Internet www.hyg.de

Unser Zeichen: W-227200-engl-13-Ho
Ansprechpartnerin: Dipl.-Ing. (FH) S. Horn

Certificate

Hygiene – Type Examination

Test institute: Hygiene Institut des Ruhrgebiets
Institut für Umwelthygiene und Toxikologie
Rotthauer Straße 21
49879 Gelsenkirchen

Test object: air handling units with heat recover type HRglobal

Manufacturer: P. LEMMENS COMPANY S.A
Parc industriel de Sauvenière
102, Chaussée de Tirlemont
B 5030 GEMBLOUX

Basis of the examination: ✓ VDI 6022, Blatt 1 (07/2011)
✓ SWKI VA104-01 (04/2006)

Validity period: 5 years 03/2013 – 03/2018

Test report: W-206730-11-Ho



In conclusion it can be stated that the examined air handling units with heat recover type HRglobal, as specified in the test report W-206730-11-Ho, are in compliance with the above mentioned regulations.

(Priv.-Doz. Dr. G.-J. Tuschewitzki)
Head of the Department of Water Hygiene
and Environmental Microbiology

(Dipl.-Ing. (FH) S. Horn)
Department of Water Hygiene
and Environmental Microbiology

issued 06.03.2013, Gelsenkirchen

Within the framework of the hygiene-type examination the hygiene-relevant requirements of the above mentioned regulations was examined. Requirements of other regulations that refer to the above mentioned regulations were not part of the examination. Additionally, the type test does not include a toxicological or sensory testing of the introduced materials.